



# Daily In-Progress Combustion Safety Test Form

REV 1/21/2020  
BPI1200

Client		Work Dates			
Job #		Technician			

**Designate Combustion Appliances to be spillage tested by work crew at end of work day**

TEST	Appliance	Location
	App 1:	
	App 2:	

<b>Confirm CO Detectors are in place and operational</b>	yes / no	<b>If no install</b>
--	----------	----------------------

**NOTE: If Combustion Appliance doesn't have a Draft Hood or Barometric Damper it is not necessary to perform worst case test**

### Set up CAZ in Worst Case Depressurization

- Place all combustion appliances located within the CAZ in their standby mode and prepare for operation
  - Set up manometer CAZ WRT Outside
  - Fires in woodstoves and/or fireplaces shall be fully extinguished, dampers closed
  - Close all building exterior doors and windows
  - Close all CAZ doors. *Close the interior doors of all rooms except rooms with an exhaust fan or forced air return.*
  - Turn on exhaust equipment: clothes dryers, range hoods, and other exhaust fans.
  - Turn on central forced air blower, *if CAZ goes more negative with blower on leave on, more positive turn off*
  - Open the CAZ door, if CAZ goes more negative leave open, if not leave closed
- |    |   |          |          |          |          |           |          |
|----|---|----------|----------|----------|----------|-----------|----------|
| 9  | Turn on Appliance                                   | Day One  |          | Day Two  |          | Day Three |          |
|    |   | App 1    | App 2    | App 1    | App 2    | App 1     | App 2    |
| 10 | Did the equipment spill gasses for more than 2 min? | yes / no | yes / no | yes / no | yes / no | yes / no  | yes / no |

**If answer is "yes," ACTION is required.**

### Action

Describe ACTION Taken and Notify Client	Initials	Date

Notes:

---



---



---



---