

# Energy Efficiency Now

---

Plenary Talk

# Purpose of a White Paper?

---

- Record collective recommendations for future reference
- Share statistical key findings of all 1200+ audits
- Compare audit results and perspectives
- Summarize common issues and recommendations
- Discuss lessons learned so mistakes are not repeated
- Illustrate issues with case studies
- Provide statistical basis for taking action



# Potential Users of White Paper

---

- Building owners and operators
- Building designers
- AHFC
- Statewide policy makers

# Building Statistics

---

- Candidate buildings from all areas of the state by ANCSA regions
- Only publically owned buildings were eligible for audits
- 1,200 buildings got energy benchmark studies performed
- 327 Investment Grade Audits (IGA) performed
- 13.7 million SF were audited
- Average building is 33 years old, schools are 35 years old
- Average building area is 41,864 SF

# Audit Statistics

---

- \$49 million/year spent on energy
- Energy Use Index (EUI) ranges 33,000 BTU/SF to 1.97 million BTU/SF
- EUI average is 149,372 BTU/SF
- Energy cost index (ECI) ranges \$.68/SF to \$32.96/SF: \$4.45/SF Av
- Average project energy savings is \$25k/year, \$125 million in total
- Energy cost ranges from \$.08/kWh to \$.80/kWh
- Energy cost per student varies from \$190/student/yr to 16k/student/yr



# Auditor Statistics

---

- AHFC selected 4 Technical Service Providers (TSP) based on qualifications
- TSPs all had opportunity to provide fee proposals geographic areas of Ak
- Auditors must be Certified Energy Auditors (CEA) and/or Certified Energy Managers (CEM)
- TSPs met frequently in order to normalize the product and share findings

# Cold Climate Housing Research Center

---

- Set up database repository for all benchmarking
- Performed statistical analysis on data
- Developed graphics to illustrate findings
- CCHRC continues to build on data provided

# Top 5 Recommendations from RSA

---

- Upgrade lighting and lighting controls
- Install setback thermostats (WiFi if no DDC)
- Provide headbolt heater controls
- Demand control ventilation (CO2 sensors)
- Upgrade HVAC controls