




**TO:** ALL PLANHOLDERS OF RECORD.

**RE:** Request for Quotations 26-RFQ-013 Valdez Boiler Replacement

**FROM:** Andrew Morton, Administrative Services Manager, Procurement 

**PAGE(S):** Two (2), including this cover sheet.

**DATE:** June 9, 2026

Transmitted herewith is Addendum No. 1. If the Addendum is **not** received in full, please contact the Procurement Office at (907) 330-8239. If all pages of the Addendum are received, please sign this sheet and email it to AHFC's Sourcing and Contract Compliance Department at [submittals@ahfc.us](mailto:submittals@ahfc.us) or you may fax it to (907) 330-8217.

\_\_\_\_\_  
Company's Name

\_\_\_\_\_  
Company's Representative

\_\_\_\_\_  
Date

ADDENDUM NO. 1



**ADDENDUM NO. 1**  
June 9, 2026

**Request for Quotations 26-RFQ-013 Valdez Boiler Replacement**

This document forms a part of and modifies the RFQ as noted below. Offerors should acknowledge receipt of this addendum. Failure to acknowledge receipt of this addendum may subject Offerors to disqualification.

**FOR:** Alaska Housing Finance Corporation  
P.O. Box 101020  
Anchorage, Alaska 99510  
Andrew Morton (907) 330-8146

The following corrections, clarifications and/or deletions to the RFQ are hereby made a part of said documents.

This addendum consists of one (1) page.

**ADDENDUM NO. 1**

Below is the corrected information regarding the hydrostat (control device) model, found on page 1 of the Summary of Work, specifically in the 6th paragraph of section 1.1 General Description.

“Contractor to provide and install **HydroStat 3250-Plus** three function control; control to receive TT signal from existing TACO Zone Valve Controller; Burner control to run in series through the Tjernlund SS1 and secondary high limit aquastat prior to powering the burner. Pump control shall be wired through the Zone Valve Controller.”

**END OF ADDENDUM NO. 1**